

Repairs on Inhouse and IBS RE : Condensaion

Address	Date Recoreded	Notes
6 Quantock Close	18/05/2004	Biocheck bathroom walls
10 Quantock Close	11/11/2004	Condensation on windows - advised tenant on condensation and leaflet given.
11 Quantock Close	10/02/2003	Condensation kit fitted
26 Quantock Close	09/03/2009	Mould on stairwell - no response to CIS and letter
26 Quantock Close	08/12/2005	Hallway walls get wet when it rains - tenant advised its condensation. Advised on condensation and leaflet given.
26 Quantock Close	11/01/2005	Dampness in hallway. Advised it is condensation.
29 Quantock Close	07/09/2008	Damp in bedroom wall - tenant advised it old water stain
52 Quantock Court	01/04/2008	Stain block kitchen ceilings
7 Quantock Close	10/11/2009	Condensation on all windows and bedroom walls - Removed mould and applied fungicide
19 Quantock Close	14/04/2010	Removed mould and applied fungicide in bedroom
40 Quantock Court	07/07/2010	Removed mould and applied fungicide in kitchen and bathroom